

ADDITIONAL HEALTH INFORMATION

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

(A) **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

(B) **Inorganic contaminants**, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

(C) **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

(D) **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

(E) **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. The Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's **Safe Drinking Water Hotline at 1-800-426-4791**.

For Customer with Special Health Concerns

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the **Safe Drinking Water Hotline (1-800-426-4791)**.

SOURCE WATER ASSESSMENT PLAN

In 2021, the Department of Environmental Protection performed a Source Water Assessment on our system and a search of the data sources indicated 129 potential sources of contamination with susceptibility level ranging from low to moderate. The assessment results are available on the FDEP Source Water Assessment and Protection Program website at www.dep.state.fl.us/swapp

HOW TO REACH US

If you have any questions about this report or concerning your water utility, please contact U.S. Water Services Corporation at (727) 848-8292. We encourage our valued customer to be informed about their water utility.

ABOUT LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hawaiian Isles is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

CITY OF ATLANTIS 2021 ANNUAL DRINKING WATER QUALITY REPORT PWS ID # 4500068

We're pleased to provide you with this year's Annual Water Quality Report. We want to keep you informed about the quality water and services we have delivered to you over the past year. Our goal is and always has been, to provide to you a safe and dependable supply of drinking water.

We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. If you have any questions or concerns about the information provided in this report, please feel free to call any of the numbers listed.

This report shows our water quality results and what they mean.

WHERE YOUR WATER COMES FROM

Atlantis receives its water from Palm Beach County Water Utilities. PBCUD operates four water treatment plants serving the distribution system to which the City of Atlantis is connected, they have wells approximately 150 feet underground in the Surficial Aquifer. The plants are staffed 24 hours a day by state-licensed water plant operators. The Department is continually upgrading its facilities to utilize the most effective and up-to-date technologies for water treatment, such as state-of-the-art membrane softening, lime softening, filtration, and disinfection by ammonia and chlorination.

HOW WE ENSURE YOUR DRINKING WATER IS SAFE

We routinely monitor for contaminants in your drinking water according to Federal and State laws, rules, and regulations. Except where indicated otherwise, this report is based on the results of our monitoring for the period of January 1 to December 31, 2021. Data obtained before January 1, 2021, and presented in this report are from the most recent testing done in accordance with the laws, rules, and regulations. As authorized and approved by the EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from one year to another. As a result some of our data is more than

As authorized and approved by the EPA, the State has reduced monitoring requirements for certain contaminants to less often than once per year because the concentrations of these contaminants are not expected to vary significantly from one year to another. As a result some of our data is more than one year old.

How to Read the Table

In the table, you may find unfamiliar terms and abbreviations. To help you better understand these terms we've provided the following definitions.

Action Level (AL): The concentration of contaminants which, if exceeded, triggers treatment or other requirements that a water system must follow.

Locational Running Annual Average (LRAA): the average of sample analytical results from samples taken at a particular monitoring location during the previous four calendar quarters.

Maximum contaminant level or MCL: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum contaminant level goal or MCLG: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

ND: Means not detected and indicates that the substance was not found by laboratory analysis.

ppm: parts per million or milligrams per liter is one part by weight of analyte to one million parts by weight of the water sample.

ppb: parts per billion or micrograms per liter is one part by weight of analyte to one billion parts by weight of the water sample.

pCi/l: picocuries per liter is a measure of the radioactivity in water.

Table Notes:

- A. Results in the Level Detected column for radiological contaminants and inorganic contaminants are the highest detected level at any sampling point.
- B. For chlorine, the level detected is the highest running annual average (RAA), computed quarterly, of monthly averages of all samples collected. The range of results is the range of results of all the individual samples collected during the past year.

2021 Water Quality Table – PWS No. 4500068

RADIOACTIVE CONTAMINANTS – PALM BEACH WATER UTILITIES							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Radium 226 + 228 or combined radium (pCi/L)	05/2020	N	1.08 + 0.562	ND – 1.08 + 0.562	0	14	Erosion of natural deposits
INORGANIC CONTAMINANTS – PALM BEACH WATER UTILITIES							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL Violation Y/N	Level Detected	Range of Results	MCLG	MCL	Likely Source of Contamination
Barium (ppm)	05/2020	N	0.0073	0.00396 – 0.0073	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Fluoride (ppm)	05/2020	N	0.927	0.129 – 0.927	4	4	Erosion of natural deposits; discharge from fertilizer and aluminum factories. Water additive which promotes strong teeth when at the optimum level of 0.7 ppm
Sodium (ppm)	05/2020	N	54.5	15.7 – 54.5	N/A	160	Salt water intrusion, leaching from soil
Lead (point of entry) (ppb)	05/2020	N	1.72	Nd – 1.72	0	15	Residue from man-made pollution such as auto emissions and paint; lead pipe, casing, and solder
Nitrate (as Nitrogen) (ppm)	05/2020	N	0.052	Nd – 0.052	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits

STAGE 2 DISINFECTION BY-PRODUCTS – PALM BEACH WATER UTILITIES							
Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Haloacetic Acids (five) (HAA5) (ppb)	2/21,5/21,8/21,11/21	N	34.3	59 – 35.4	N/A	MCL = 60	By-product of drinking water disinfection
TTHM [Total trihalomethanes] (ppb)	2/21,5/21,8/21,11/21	N	48.4	11.9 – 48.1	N/A	MCL = 80	By-product of drinking water disinfection

LEAD AND COPPER (TAP WATER)							
Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	AL Exceeded Y/N	90th Percentile Result	No. of sampling sites exceeding the AL	MCLG	AL (Action Level)	Likely Source of Contamination
Copper (tap water) (ppm)	12/2020	N	0.278	0	1.3	1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
Lead (tap water) (ppb)	12/2020	N	1.95	1	0	15	Corrosion of household plumbing systems, erosion of natural deposits

STAGE 1 DISINFECTANTS							
Disinfectant or Contaminant and Unit of Measurement	Dates of sampling (mo./yr.)	MCL or MRDL Violation Y/N	Level Detected	Range of Results	MCLG or MRDLG	MCL or MRDL	Likely Source of Contamination
Chlorine (ppm)	Monthly 2021	N	2.26	0.93 – 3.3	MRDLG = 4	MRDL = 4.0	Water additive used to control microbes
STAGE 2 DISINFECTION BY-PRODUCTS							
Haloacetic Acids (five) (HAA5) (ppb)	08/2021	N	27	N/A	N/A	MCL = 60	By-product of drinking water disinfection
TTHM [Total trihalomethanes] (ppb)	08/2021	N	58.6	N/A	N/A	MCL = 80	By-product of drinking water disinfection